



Certificate of Compliance

Certificate: 1001740 (LR
22355-25,-26,-27)

Master Contract: 162037

Project: 1465912
Issued to: Barksdale, Inc.

3211 Fruitland Ave.
Los Angeles, California 90058
USA
Attention: Alan Mason

Date Issued: August 20, 2003

The products listed below are eligible to bear the CSA Mark shown



Gerard Cerbu

Issued by: Gerard Cerbu, P. Eng.

PRODUCTS

CLASS 3231 02 - SWITCHES - Automatic - Pressure Type

Pressure switches, stripped, open type, Model MSPS, CMSPS, followed by DD, JJ, EE, FF, KK, LL or XX followed by 05, 15 or 100, may be followed by SS, and/or may be followed by V, E or N, and/or P1 through P10, PLS and/or Q1 through Q99, rated; with Suffixes DD and JJ: 15A at 125V ac or 250V ac, 1/2A at 125V dc 1/4A at 250V dc; MSPS-JJ15-Q34, MSPS-JJ100-Q37, MSPS-JJ100-Q41: 11A, 250V ac; 0.5A, 125V dc; 0.25A, 250V dc, with Suffix EE or FF: 3A at 125V ac or 250V ac; Suffix KK: 21A at 125V ac or 250V ac; Suffix LL: 25A at 125V ac or 250V ac, with Suffix XX ratings per (not to exceed) Certified component HONEYWELL (Micro Switch) V3 or V7 Series or Omron D3V, V or VX Series

Snap switch.

Notes:

Note: Open type devices are Certified as Components for use only in other Certified equipment where the suitability of the combination is to be determined by the CSA International.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14 - Industrial Control Equipment