



# Certificate of Compliance

**Certificate:** 1447886 (LR22355)

**Master Contract:** 162037

**Project:** 1575222

**Date Issued:** August 20, 2004

**Issued to:** Barksdale, Inc.  
3211 Fruitland Ave.  
Los Angeles, California 90058  
USA  
Attention: Mr. Alan Mason

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** Gerry Cerbu, P.Eng.

**Authorized by:** Gabriel Lipka, C.E.T., Product Group Manager

A handwritten signature in black ink, appearing to read 'Gabriel Lipka'.

## **PRODUCTS**

### **CLASS 3231 02 - SWITCHES - Automatic - Pressure Type**

Pressure Operated Switches, 7000 series Cat. No 7 followed by 1,2 or 3, followed by 0 through 7, followed by S, F, P or B, followed by 1, 2, 3, 4, 5, 6, 7, 8, 9 or X, followed by 1 through 8, followed by 1 through 4, followed by B, V, N, E or D, followed by 1 through 3000, followed by R or F, or S0001 through S9999, followed by Q1 through Q99, W01 through W999, or Z1.

Electrical ratings are as follows:

Electrical –

Models with suffix 3, 8, 9: 125/250 V ac, 11 A, general use, 75°C (167°F)

Models with suffix 1, 4, 5: 125/250 V ac, 5 A, general use, 85°C (185°F)

Models with suffix 2, 6, 7: 125/250 V ac, 0.1 A, general use, 85°C (185°F)



**Certificate:** 1447886 (LR22355)

**Master Contract:** 162037

**Project:** 1575222

**Date Issued:** August 20, 2004

---

Pressure - See Nomenclature for pressure ratings.

Notes:

The 7000 Series is for use only in products where the acceptability of the combination is determined by CSA International

**APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No. 14-95 - Industrial Control Equipment

UL Std No. 508 - Industrial Control Equipment