



Certificate of Compliance

Certificate Number: LR 45322-49

Revision: LR 45322-81

Date Issued: April 4, 1997

Issued To: DYNALCO CONTROLS
A UNIT OF MARK CONTROLS CORP
3690 N W 53RD ST
P O BOX 5328
FT LAUDERDALE FL 33310
USA
Attention: Mr. Rolly Ingles

The products listed below are eligible to bear the CSA Mark.

Issued By: Y. Khitrov, P. Eng.
Toronto, ON Canada

Signature

CLASS 2258 03 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non-Incendive Systems - For Hazardous Locations

PRODUCTS

Class I, Groups C and D:

- Magnetic pick-ups Models M104, M134, M135, M139, M140, M160, M180, M201, M202, M203, M204, M205, M231, M233, M337, M342 and M341, intrinsically safe when connected through Dynalco shunt diode safety barrier ISB-101 per Dynalco Dwg A8003542.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No.	142-M1987	-	Process Control Equipment
CAN/CSA-C22.2 No.	157-92	-	Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations