

Certificate of Compliance

Certificate: 1205518 (LR 45322-33)

Master Contract: 155891

Project: 1205518

Date Issued: July 25, 2001

Issued to: DYNALCO CONTROLS
A Unit of Mark Controls Corporation
3690 N. W. 53 St.
Fort Lauderdale, FL 33309-2478
USA
Attention: Mr. Dale Leideker

The products listed below are eligible to bear the CSA Mark shown, with adjacent indicator "C" and "US".



Issued by:

M. Banu
M. Banu, P. Eng.

Authorized by:

B. Rossborough
B. Rossborough
Operations Manager

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations - CERTIFIED TO U.S. STANDARDS

Class I, Div 2, Groups C and D:

Speed switch Series SST-2000H, rated 0.3A at 30V dc and 120V ac, 0.2A at 230V ac, relay output contacts rated 5A at 24V dc, 1A at 120V ac, 0.5A at 220V ac.

The "C" and "US" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S. This includes products eligible to bear the NRTL indicator. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognised to perform certification to U.S. Standards.

Certificate: 1205518 (LR 45322-33)



Master Contract: 155891

Project: 1205518

Date: July 25, 2001

CLASS 2252 01 - PROCESS CONTROL EQUIPMENT

Speed switch Series SST-2000A, -2200A, -2400A, open, input, 120V ac, 5W, relay output, 6A, 28V dc/300V ac.

Note: These speed switches are Certified as components for use in other CSA Certified equipment where the suitability of the combination is determined by CSA International or local inspection authority.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No.	14-M91	- Industrial Control Equipment
CSA Std C22.2 No.	142-M1987	- Process Control Equipment
CSA Std C22.2 No.	213-M1987	- Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
UL	3121-1998	- Process Control Equipment
UL	1604 -1995	- Electrical Equipment for Use in Class I and Class II, Division 2, and Class III Hazardous (Classified) Locations

MARKINGS

- CSA Monogram with "C/US" indicator;
- Company name;
- Model number;
- Serial number;
- Electrical rating;
- Hazardous locations designation;
- Temperature Code Rating;
- Caution re substitution of components.



Supplement to Certificate of Compliance

Certificate: 1205518 (LR 45322-33)

Master Contract: 155891

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
1205518	July 25, 2001	Revised construction and update to include US Certification and Group C.
-65	April 14, 1994	Update to LR 45322-33 to cover transfer of speed switch Series SST-2000A, -2400A for general non-hazardous locations from LR 92270.
-44	Feb. 20, 1992	Revised Construction for equipment covered under LR 45322-28, -29, -33 and -37.
-33	July 3, 1990	Speed Switch SST-2000H Series for Class I, Div 2, Group D.